

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-0630:110 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Fyrnetics, 1055 Stevenson Ct #102W, Roselle IL 60172
Contact: Larry Ratzlaff (847) 742-5165*

DESIGN: Model 120X relay module. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, voltage rating and UL label.

APPROVAL: Listed as a relay module for use with Model 1235, 1275, 1285 ionization smoke detector (CSFM Listing No. 7271-0630:112) and Model PE120 photoelectric smoke detector (CSFM Listing No. 7272-630:116) and HD135F heat detector (CSFM Listing No. 7254-0630:114). Module is not recommended for use with automatic dialers and is not to be used as a method of increasing the maximum number of smoke alarms permitted in multiple station operation.

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 10, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager